

**Certificate Number:** AZ 69027500

Page: 0001



## CERTIFICATE OF APPROVAL

**Authorised marking:** TUV-027500-EA

TÜV Rheinland Australia Pty Ltd "Electrical Product Safety Certification (EPSC) Scheme", accredited by JAS-ANZ in accordance with ISO/IEC 17065, has issued this certificate under the Gas and Electricity (Consumer safety) Act 2017 as a declared Recognised External Approval Scheme (REAS). The electrical equipment described hereunder has been evaluated and found to be electrically safe at the time of certification. It is a requirement that all equipment supplied under this certificate shall be identical to the equipment as certified. The certificate holder shall place the above mentioned authorised marking on the product. The certificate holder may use the Regulatory Compliance Mark (RCM) provided all the requirements of AS/NZS 4417.1 & AS/NZS 4417.2 applicable to the article are fulfilled.

### CERTIFICATE HOLDER:

Cables Pte Ltd  
17 Leonidas Street  
Lautoka, Fiji Islands  
Fiji

### DESCRIPTION OF EQUIPMENT

**Declared class:**

BUILDING WIRING CABLE

**Product:**

Electric Cable

**Trade Name / Manufacturer:**

Pacific Cables

**Model Number:**

PC series

Model number refer to CONTINUATION SHEET 1 and 2

**Ratings:**

450/750V, ratings refer to CONTINUATION SHEET 1 and 2

**Standard:**

AS/NZS 5000.2:2006

**Issue Date:**

27/09/2023

**Expiry Date:**

27/09/2028

*Signed for and on behalf of TÜV Rheinland Australia Pty Ltd*

A handwritten signature in blue ink, appearing to read "Grant Li".

Grant Li



[www.jas-anz.org/register](http://www.jas-anz.org/register)

**Certificate Number:** AZ 69027500

Page: 0002



## CERTIFICATE OF APPROVAL

Authorised marking: TUV-027500-EA

### CONTINUATION SHEET 1

Model number for PC series cable:

PC2010, 2C, 2x1.0mm<sup>2</sup>, V-90 insulated, and 3V-90 sheathed 450/750V, flat electric cable with Class 1 plain annealed copper conductors.

PC2015, 2C, 2x1.5mm<sup>2</sup>, V-90 insulated, and 3V-90 sheathed 450/750V, flat electric cable with Class 2 plain annealed copper conductors.

PC2025, 2C, 2x2.5mm<sup>2</sup>, V-90 insulated, and 3V-90 sheathed 450/750V, flat electric cable with Class 2 plain annealed copper conductors.

PC3100, 2C+E, 2x1.0mm<sup>2</sup> + 1.5mm<sup>2</sup>, V-90 insulated, and 3V-90 sheathed 450/750V flat electric cable with Class 1 plain annealed copper conductors for phase and Class 2 copper conductors for earth.

Issue Date: 27/09/2023

Expiry Date: 27/09/2028

*Signed for and on behalf of TÜV Rheinland Australia Pty Ltd*

A handwritten signature in blue ink, appearing to read "Grant Li", positioned above a horizontal line.

Grant Li



[www.jas-anz.org/register](http://www.jas-anz.org/register)

**Certificate Number:** AZ 69027500

Page: 0003



## CERTIFICATE OF APPROVAL

Authorised marking: TUV-027500-EA

### CONTINUATION SHEET 2

Model number for PC series cable:

PC3150, 2C+E, 2x1.5mm<sup>2</sup> + 1.5mm<sup>2</sup>, V-90 insulated,  
and 3V-90 sheathed 450/750V flat electric cable with Class 2  
plain annealed copper conductors.

PC3250, 2C+E, 2x2.5mm<sup>2</sup> + 2.5mm<sup>2</sup>, V-90 insulated,  
and 3V-90 sheathed 450/750V flat electric cable with Class 2  
plain annealed copper conductors.

PC3600, 2C+E, 2x6mm<sup>2</sup> + 2.5mm<sup>2</sup>, V-90 insulated,  
and 3V-90 sheathed 450/750V flat electric cable with Class 2  
plain annealed copper conductors.

Issue Date: 27/09/2023

Expiry Date: 27/09/2028

*Signed for and on behalf of TÜV Rheinland Australia Pty Ltd*

A handwritten signature in blue ink, appearing to read "Grant Li".

Grant Li



[www.jas-anz.org/register](http://www.jas-anz.org/register)